

**JORDAN VALLEY WATER CONSERVANCY DISTRICT
JNPS VALVE REPLACEMENT PROJECT
DISTRICT PROJECT NO. 4401**

October 2025

ADDENDUM NO. 1

PART 1 – GENERAL

- A. The following ADDENDUM shall be made part of the Bidding Documents, and the Bidder shall acknowledge receipt thereof on page C-1 of the BID. The addendum consists of 2 pages.
- B. This addendum does change the bid date. It is now Monday, Oct 27, 2025, at 2:00 P.M.

1.1 CHANGES TO BID DOCUMENTS

- 1.1.1 General Conditions have been added to Bid Documents, consisting of pages 1-1 to 16-1. This has been inserted on pages 41 to 102 of the PDF.
- 1.1.2 Contract has been added to Bid Documents, consisting of pages F-1 to F-6. This has been inserted on pages 21 to 26 of the PDF.
- 1.1.3 DESCRIPTION OF WORK has been changed to the following:

This project consists of removal and disposal of one (1) submerged 60-inch AWWA butterfly inlet valve gearbox and one (1) submerged 48-inch AWWA butterfly outlet valve gearbox in Basin 3 of the Terminal Reservoir. The work will also include the purchase and installation of one (1) new 60-inch AWWA butterfly valve gearbox, one (1) 48-inch AWWA butterfly valve gearbox, and the recoating of one (1) submerged 36-inch AWWA butterfly suction valve gearbox, all of which shall be rated for submersion. If the hardware on the 36-inch gearbox cannot be salvaged, it shall be replaced with stainless steel hardware. Depending on the size and configuration of the new gear boxes, they may need to be installed with a universal joint that allows for installation at a slight angle or using an adapter to maintain use the existing roof penetration to ensure proper operation and facilitate future maintenance.

This occurs on page 4 of the PDF.

- 1.1.4 RECEIPT OF BIDS has been changed to the following:

Sealed bids will be received at the office of the Jordan Valley Water Conservancy District, Owner of the Work, located at 8215 South 1300 West, West Jordan, Utah 84088, until 2:00pm, on Monday October 27 2025, for construction of the Terminal Reservoir Gearbox Replacement Basin 3. Electronic bids may also be submitted in adobe .pdf format to ellisad@jvwcd.gov. JVWCD requests that electronic bids be submitted 15 minutes prior to the bid opening deadline, to allow for verification of delivery. A public bid opening will be held at the bid due time. Attendance is not

required. Bid results will be posted to the District's website within 24 hours of the bid opening.

This occurs on page 4 of the PDF.

1.1.5 Bid schedule on page C-2 has been updated to reflect the description of work. This occurs on page 13 of the PDF.

1.1.6 Technical specifications section 01010.02 has been updated to reflect the description of work. This occurs on page 111 of the PDF.

1.2 ANSWERS TO QUESTIONS

A. Contractor may submit questions for response until Oct 23rd.

JORDAN VALLEY WATER CONSERVANCY DISTRICT

Jake Slater
Staff Engineer