

Schedule

Prebid Meeting: 4/14/2026

Bids Due: 4/22/2026 at 3:00pm

Present to Board: 6/10/2026

Notice of Award: 6/17/2026

Anticipated Notice to Proceed: 7/1/2025

Important Notes

- Concrete curb detail location dependent on existing grade more what is shown on plan.
- Protect in place all existing vaults.
- Retaining wall height will vary across the length, use single detail for all heights.
- No low points on the asphalt, all water must be directed to the drain or the outside edge.
- Provide weeping holes in retaining wall that will drain onto asphalt surface.

Questions

1. What is the size of rock needed for the granular gravel fill along road section with concrete curb?
Plan B M4 sheet 7 of 7?
 - a. The specifications for the granular gravel fill shown in detail B/M4 can be found in the specifications Section 02220 201.01 C. Note that this granular backfill will also be used behind the retaining wall as shown in detail A/M3.
2. Are we going to be able to use the existing material we ex-out for backfill against the 1' of rock behind retaining wall?
 - a. Existing material can be used against the 1' gravel backfill behind the retaining wall.

Any additional questions must be submitted by end of business day on Monday, April 20, 2026.